

Date	December 9 th 2010
Revision No.	0
Project Name	Corpus Christi Medical Center – Emergency Dept
System	RTU-1
Application No.	NC10-1341
Rep Name	Oktay Basci
Rep Office	Mechanical Reps Inc.
Engineer Name	Arthur R. Linden
Engineer Office	Redding Linden Burr – Consulting Engineers
Architect Name	--
Architect Office	--

Project Name: Corpus Christi Medical Center – Emerg Dept
Systems: RTU-1 SUP
Application No.: NC10-1341

Building Owner: --
Engineer: Arthur R. Linden
Project ID: Supply - No silencer

Path	Element	63Hz	125Hz	250Hz	500Hz	1KHz	2KHz	4KHz	Comments
Path1	Custom Element	84	86	91	86	84	81	76	RTU-1 SUP
	Straight Duct(RU1)	-1	-1	-1	0	0	0	0	
	Junction (T,atten.)	-3	-3	-3	-3	-3	-3	-3	
	SubSum	80	82	87	83	81	78	73	
	Junction (T,regen.)	0	0	0	0	0	0	0	Regenerated sound from junction.
	SubSum	80	82	87	83	81	78	73	
	Straight Duct(RU1)	-1	-1	0	0	0	0	0	
	Elbow (ul.sq.rct)	0	-1	-3	-6	-4	-4	-4	
	SubSum	79	80	84	77	77	74	69	
	Elbow (regen.)	37	35	29	21	10	0	0	Regenerated sound from elbow.
	SubSum	79	80	84	77	77	74	69	
	Straight Duct(RU1)	-2	-1	-1	0	0	0	0	
	Elbow (ul.sq.rct)	0	-1	-3	-6	-4	-4	-4	
	SubSum	77	78	80	71	73	70	65	
	Elbow (regen.)	36	34	29	20	9	0	0	Regenerated sound from elbow.
	SubSum	77	78	80	71	73	70	65	
	Junction (T,atten.)	-6	-6	-6	-6	-6	-6	-6	
	SubSum	71	72	74	65	67	64	59	
	Junction (T,regen.)	0	0	0	0	0	0	0	Regenerated sound from junction.
	SubSum	71	72	74	65	67	64	59	
	Straight Duct(RU1)	-10	-5	-3	-2	-2	-2	-2	
	Elbow (ul.rad.rct)	0	0	-1	-2	-3	-3	-3	
	SubSum	61	67	70	61	62	59	54	
	Elbow (regen.)	0	0	0	0	0	0	0	Regenerated sound from elbow.
	SubSum	61	67	70	61	62	59	54	
	Junction (T,atten.)	-4	-4	-4	-4	-3	-3	-3	
	SubSum	57	63	66	57	59	56	51	
	Junction (T,regen.)	0	0	0	0	0	0	0	Regenerated sound from junction.
	SubSum	57	63	66	57	59	56	51	
	Straight Duct(RU1)	-5	-3	-2	-1	-1	-1	-1	
	Elbow (ul.rad.rct)	0	0	-1	-2	-3	-3	-3	
	SubSum	52	60	63	54	55	52	47	
	Elbow (regen.)	0	0	0	0	0	0	0	Regenerated sound from elbow.
	SubSum	52	60	63	54	55	52	47	
	Indoor (Regression)	-8	-8	-7	-8	-9	-9	-11	
	Sum	44	52	56	46	46	43	36	


NC 47 RC 45(N) 52 dBA

Project Name: Corpus Christi Medical Center – Emerg Dept
Systems: RTU-1 SUP
Application No.: NC10-1341


Building Owner: --
Engineer: Arthur R. Linden
Project ID: Supply - With Silencer

Path	Element	63Hz	125Hz	250Hz	500Hz	1KHz	2KHz	4KHz	Comments
Path1									
	Custom Element	84	86	91	86	84	81	76	RTU-1 SUP
	Custom Element	-7	-10	-16	-22	-33	-36	-31	ERMT60/4E
	Straight Duct(RU1)	-1	-1	-1	0	0	0	0	
	Junction (T,atten.)	-3	-3	-3	-3	-3	-3	-3	
	SubSum	73	72	71	61	48	42	42	
	Junction (T,regen.)	0	0	0	0	0	0	0	Regenerated sound from junction.
	SubSum	73	72	71	61	48	42	42	
	Straight Duct(RU1)	-1	-1	0	0	0	0	0	
	Elbow (ul.sq.rct)	0	-1	-3	-6	-4	-4	-4	
	SubSum	72	70	68	55	44	38	38	
	Elbow (regen.)	37	35	29	21	10	0	0	Regenerated sound from elbow.
	SubSum	72	70	68	55	44	38	38	
	Straight Duct(RU1)	-2	-1	-1	0	0	0	0	
	Elbow (ul.sq.rct)	0	-1	-3	-6	-4	-4	-4	
	SubSum	70	68	64	49	40	34	34	
	Elbow (regen.)	36	34	29	20	9	0	0	Regenerated sound from elbow.
	SubSum	70	68	64	49	40	34	34	
	Junction (T,atten.)	-6	-6	-6	-6	-6	-6	-6	
	SubSum	64	62	58	43	34	28	28	
	Junction (T,regen.)	0	0	0	0	0	0	0	Regenerated sound from junction.
	SubSum	64	62	58	43	34	28	28	
	Straight Duct(RU1)	-10	-5	-3	-2	-2	-2	-2	
	Elbow (ul.rad.rct)	0	0	-1	-2	-3	-3	-3	
	SubSum	54	57	54	39	29	23	23	
	Elbow (regen.)	0	0	0	0	0	0	0	Regenerated sound from elbow.
	SubSum	54	57	54	39	29	23	23	
	Junction (T,atten.)	-4	-4	-4	-4	-3	-3	-3	
	SubSum	50	53	50	35	26	20	20	
	Junction (T,regen.)	0	0	0	0	0	0	0	Regenerated sound from junction.
	SubSum	50	53	50	35	26	20	20	
	Straight Duct(RU1)	-5	-3	-2	-1	-1	-1	-1	
	Elbow (ul.rad.rct)	0	0	-1	-2	-3	-3	-3	
	SubSum	45	50	47	32	22	16	16	
	Elbow (regen.)	0	0	0	0	0	0	0	Regenerated sound from elbow.
	SubSum	45	50	47	32	22	16	16	
	Indoor (Regression)	-8	-8	-7	-8	-9	-9	-11	
	Sum	37	42	40	24	13	7	5	

NC 29 RC 15(R) 33 dBA



RTU-1
SUPPLY


AIO Silencer Schedule																								
Job Name: Corpus Christi Medical Center – Emergenc																								
Engineer: Redding Linden Burr – Consulting Engineers Arthur R. Linden					Date: 6/9/2011																			
Contractor:					Job #: QP00000430																			
Customer: Mechanical Reps Inc.					Revision:					Page: 1 of 1					Units: Imperial									
Bank Information										Duct System Information					Dynamic Insertion Loss (dB) / Generated Noise									
Tag	Qty	Model	Width in.	Height in.	Duct Dia. in.	Length in.	Leg A in.	Leg B in.	Direction	Velocity fpm	Flow cfm	PD in. w.g.	PD w/ SE in. w.g.	63	125	250	500	1K	2K	4K	8K			
RTU-1 SUP	1	ERMT60/4E	20	38	--	60	40	40	Forward	866	4570	0.37	--	7	10	16	22	33	36	31	23			
Construction Notes: 18 gauge galvanized casing, 22 gauge galvanized perforated liner, glass fiber acoustic media, Mylar film bagged, acoustic standoff, 1" Slip connection														48	46	40	41	41	35	37	29			

Notes:


- Performance data is derived from test values obtained in accordance with ASTM E477-06a.
- The installed silencer may have increased pressure drop resulting from system effect caused by duct elements located upstream or downstream of the silencer.
- Dynamic insertion losses are limited to 55 dB due to flanking. Please contact your local Price representative if insertion loss values greater than 55 dB are required.
- All material used in the construction of Price silencers meets or exceeds a flame spread classification of 25 and a smoke development rating of 50 when tested in accordance with ASTM E84, UL723 and NFPA255.

SILENCER BANK INFORMATION				COMPONENT INFORMATION			
Quantity:	1	Width (in.):	20	Center Line (in.):	60	Quantity:	1
Model:	ERMT60/4E	Height (in.):	38	Inlet Leg (in.):	40	Width:	20
Weight (lb):	180	Configuration:	Un-nested	Outlet Leg (in.):	40	Height:	38


BANK CONFIGURATION



END VIEW



TOP VIEW



ISO VIEW

Images are generic representations of the silencer. The actual configuration may not be as shown.

PERFORMANCE

AIRFLOW		DYNAMIC INSERTION LOSS (dB)							
Air Volume (cfm):	4570	63 Hz	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz
Air Velocity (fpm):	866	7	10	16	22	33	36	31	23
Direction:	Forward	GENERATED NOISE (dB)							
Pressure Drop (in. w.g.):	0.37	63 Hz	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz
		48	46	40	41	41	35	37	29

SILENCER CONSTRUCTION OPTIONS

Casing: 18 GA Galvanized	Acoustic Media: Glass Fiber	Inlet Connection: 1" Slip
Perforated Liner: 22 GA Galvanized	Media Protection: Mylar Film Bagged	Outlet Connection: 1" Slip

NOTES

- Performance data is derived from test values obtained in accordance with ASTM E477-06a.
- The installed silencer may have increased pressure drop resulting from system effect caused by duct elements located upstream or downstream of the silencer.
- Dynamic insertion losses are limited to 55 dB due to flanking. Please contact your local Price representative if insertion loss values greater than 55 dB are required.
- All material used in the construction of Price silencers meets or exceeds a flame spread classification of 25 and a smoke development rating of 50 when tested in accordance with ASTM E84, UL723 and NFPA255.
- Acoustic Standoff is provided standard with film liner media protection options.

PROJECT: Freestanding Emerg Dept		 ERMT60/4E Elbow Silencer Absorptive
ENGINEER:	Units of Measure: Imperial	
CUSTOMER:	Rev. Level:	
SUBMITTAL DATE: 12/13/2010	Tag: RTU-1 SUP	